



# Water Systems Product “Typical Specifications ASME Vessels”

## **WX-400-C Series (Diaphragm type pre-pressurized)**

The water system shall include a WELL-X-TROL®, diaphragm-type pre-pressurized storage tank Model No.\_\_\_\_\_. Dimensions shall be as indicated on the drawings.

The storage tank shall be welded steel, constructed, tested and stamped in accordance with Section VIII, Division 1 of the ASME Code for a working pressure of (125 psig / 8.8 kg/cm<sup>2</sup>) (150 psig / 10.5 kg/cm<sup>2</sup>) (175 psig / 12.3 kg/cm<sup>2</sup>) (250 psig / 17.6 kg/cm<sup>2</sup>) (\_\_\_\_\_) and air pre-charged.

The tank shall be supported by steel legs or a base (integral ring mount) for a vertical installation. Each tank will have a heavy- duty butyl/EPDM diaphragm with code approvals ANSI/NSF 61. Each tank shall have a polypropylene liner. The vessel (s) shall be painted with one shop coat of red oxide primer.

The manufacturer shall be AMTROL Inc. The manufacturer shall have at least five years experience in the fabrication of diaphragm-type ASME tanks.

## **WX 440-C / 450-C (bladder-type pre-pressurized)**

The water system shall include a WELL-X-TROL®, bladder-type pre-pressurized storage tank Model No.\_\_\_\_\_. Dimensions shall be as indicated on the drawings.

The storage tank shall be welded steel, constructed, tested and stamped in accordance with Section VIII, Division 1 of the ASME Code for a working pressure of (125 psig / 8.8 kg/cm<sup>2</sup>) (150 psig / 10.5 kg/cm<sup>2</sup>) (175 psig / 12.3 kg/cm<sup>2</sup>) (250 psig / 17.6 kg/cm<sup>2</sup>) (\_\_\_\_\_) and air pre-charged.

The tank shall be supported by steel legs or a base (integral ring mount) for a vertical installation. Each tank will have a heavy- duty butyl bladder with code approvals ANSI/NSF 61. The bladder shall have a minimum thickness of 0.100 inches. The vessel (s) shall be painted with one shop coat of red oxide primer.

The manufacturer shall be AMTROL Inc. The manufacturer shall have at least five years experience in the fabrication of bladder-type ASME tanks.



w w w . a m t r o l . c o m

Corporate Headquarters  
1400 Division Road  
West Warwick, RI 02893  
Telephone: 401-884-6300  
Fax: 401-884-5276

AMTROL Canada, Ltd.  
275 Shoemaker Street  
Kitchener, Ontario N2E 3B3  
Telephone: 800-256-3188  
Fax: 519-748-4321

